



**Tender No -110269/WGI/AGL/10-R0**

**Replies to Bidders Queries  
Dtd. 24.03.2010**

<b>Sr No</b>	<b>Section Detail</b>	<b>Bidder Queries</b>	<b>WGI / AGL Replies</b>
1	NIT 1.1 Page 1 of 1	The bidder should have executed a part of city gas project or one work order for a City Gasof value of Rs. 25 Lakh in a single order.Kindly consent the Work Order Limit from 25 Lakh To 10 Lakh.	Tender Conditions Prevail
2	Vol II of II	The Standard Drawing of Main Gate and Installation of barbed wire fencing is not enclosed / available with this tender document.	Attached as Annexure-I
3	Vol II of II	List of approved vendor list is not given with this bid document. Please provide.	Attached as Annexure-II
4	SOR -A & B1.12	Grade of Concrete is not specified for RCC of Valve Pit.	As per STD drawing attached in tender Dwg No. STD-19-142
5	SOR-A & B 1.13	The mesh sizes are available in width of 1.8m or say 6feet and as SOR stipulate that it shall be of 2.0m and type of test certificate required for barbed wore fencing. Kindly clarify the exact size of the mesh.	As per availability and IS 278