



**CITY GAS DISTRIBUTION PROJECT
TENDER FOR SUPPLY OF PE FITTINGS AND VALVES
REPLIES TO BIDDERS QUERIES**



Tender No: 110290/WGI/GAIL GAS /30-R0

Dtd. 12.01.2011

Sr. No.	Section / Clause No.	Tender Doc. Page No.	Clause Description	Clarification Required	Clarifications
1.	Vol. II of II Technical specification & SOR	Page 3 of 6 (Section -1, Vol. II of II	Supply of fittings – technical spec.	It is not clear from the SOR or technical specification that extra couplers / reducers for the spigot end of the transition fittings, equal tee & reducing tee are to be included or not ? this will have impact on pricing of the final product.	Extra coupler / reducers are to be included For the spigot end of the transition and other fittings wherever required.
2.	Vol. II of II Technical specification & SOR	Page 3 of 6 scope of supply item no 6&7	Supply of Reducing Tee	There is no any direct reducing tee for 180 x 125 & 125 x 32 mm sizes, in such cases it is industry practice to supply combination of EF equal tees & EF reducer. This will also allow spigot end to supplied with electro fusion reducers if you require extra electro fusion coupler at spigot end.	Tender condition prevails.
3	Vol. II of II Technical specification	Page 7 of 20 Technical specification	cl.5.1 Length positioning 60 mm	Fusion fittings inbuilt positioning provision length to be corrected as 63 mm as per std.	Bidder to provide inbuilt positioning system as per requirement as specified in PNGRB specification and tender specification.
4	Vol. II of II Technical specification	Page 10 of 20 Technical specification	cl.6.3 Color	Colour of fittings Orange	Refer Corrigendum-1