



CND AND CITY GAS DISTRIBUTION PROJECT
TENDER FOR SUPPLY OF CNG CASCADE
CORRIGENDUM – 1



TENDER No. – 110304/WGI/GAIL GAS/09-R0

DATE: 09.08.2011

Sr. No.	Section / Clause No.	Tender Doc. Page No.	Clause Description	Added / Modified / Deleted
1.	IFB 1.2.6	2 of 118	Last date and time for submission of bid	Extended up to "19.08.2011"
2.	IFB 1.2.7	2 of 118	Date and time of opening of Un-priced Bids at WGI office, New Delhi	Extended up to "19.08.2011"
3				Revised SOR attached

Corrigendum-1 is to be treated as part of the original Tender document and while submitting your offer; Corrigendum-1 shall also be signed, stamped and submitted along with Tender Document.

REPLIES TO BIDDERS QUERIES

Sr. No.	Section / Clause No.	Tender Doc. Page No.	Clause Description	Clarification Required	Clarifications
1.	Vol. II of II Technical specification	Page 8 of 13	Working Pressure	Our cascade's cylinders working pressure is 255 Kg/Cm2 at 15 °C in place of 255 bar at 15°C as required by you	Acceptable. Working Pressure of Cascade Cylinder shall be minimum 250 barg at 15 degree C.